

Certificate of Constancy of Performance



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Basis:
EN 179:2008-01

Emergency exit devices

mFlipLock, sFlipLock

Emergency exit locks with lever handle operation for single and double leaf doors

According to configuration in annex 1

Product description/
specification

Levels and classes of
performance

According to configuration in annex 1

Intended use(s)

Intended for use on doors in escape routes with requirements for fire resistance and smoke control

placed on the market
under the name or trade
mark of

ASSA ABLOY (Schweiz) AG Schlosstechnik

Laufenstr. 172, CH-4245 Kleinlützel

and produced in the
manufacturing plant(s)

ASSA ABLOY (Schweiz) AG Schlosstechnik

Laufenstr. 172, CH-4245 Kleinlützel

Notified body No.
EC-Reference-No.

0757

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 179 : 2008


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 13.12.2017 and will remain valid until 12.12.2023, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 229PANIK 6039631.



Christian Kehrer
Head of notified product certification body
ift Rosenheim
02.01.2023



www.ec.europa.eu

Identity check



www.ift-rosenheim.de/
ift-zertifiziert
ID: 2B6-46F33

Certificate of constancy of performance

Annex 1 Page 1 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

1. Emergency exit devices as per EN 179 : 2008 for single leaf doorsets: handle operation

Classification:	3	7	6	B	1	3	2	2	A	B/D
------------------------	----------	----------	----------	----------	----------	----------	----------	----------	----------	------------

for Assa Abloy:

Backset 30 up to 80 mm
Distance 92 mm for PZ and 94 mm for RZ
Forend (18 up to 24) mm x 3 mm

for Wicona:

Backset 35 und 45 mm
Distance 92 mm for PZ and 94 mm for RZ
Forend 22 mm x 3 mm

Intended use: Intended for use on doors in escape routes with requirements for fire resistance and smoke control

Reference-report: 17-000296-PR03 dated 06.09.2021
Reference-report: 17-000296-PR08 dated 06.09.2021

Certificate of constancy of performance

Annex 1 Page 2 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Locks:

- mFlipLock basis
- mFlipLock standard
- mFlipLock check contact lock
- mFlipLock drive motor lock
- mFlipLock access motor lock
- mFlipLock e-drive handle controlled
- mFlipLock e-access handle controlled

Family	Designation Assa Abloy
mFlipLock / basis	23444PE .6 / .7
	23446PBa .2 / .3
	23446PBe .2 / .3
mFlipLock / standard	24444HR-PE .6/.7
	24444PE .6 / .7
	24444PE-TF .6/.7
	24446PBa .2 / .3
	24446PBe .2 / .3
	24446HR-PBa .2 / .3
	24446HR-PBe .2 / .3
	24544HR-PE-SV .6 / .7
	24544HR-PE-SV-TF .6 / .7
	24544M-HR-PE-SV.6 / .7
	24544M-PE-SV.6 / .7
	24544PE-SV .6 / .7
	24544PE-SV-TF .6 / .7
	24546PBa-SV .2 / .3
	24546PBe-SV .2 / .3
	24546HR-PBa-SV .2 / .3
24546HR-PBe-SV .2 / .3	
mFlipLock check / contact lock	24576PBa-SV-FF .6/.7
	24576PBe-SV-FF .6/.7
	24574HR-PE-SV-TF .6/.7
	24574HR-PE-SV-FF .6/.7
	24474PE .6 / .7
	24474HR-PE .6 / .7
	24476PBa .6 / .7
	24476PBe .6 / .7
	24476HR-PBa .6 / .7
	24476HR-PBe .6 / .7
	24576HR-PBa-SV-FF .6/.7
	24576HR-PBe-SV-FF .6/.7
	24574PE-SV .6 / .7

Certificate of constancy of performance

Annex 1 Page 3 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

	24574PE-SV-FF .6 / .7
	24574PE-SV-TF .6 / .7
	24574HR-PE-SV .6 / .7
	24576PBa-SV .2 / .3
	24576PBe-SV .2 / .3
	24576HR-PBa-SV .2 / .3
	24576HR-PBe-SV .2 / .3
mFlipLock drive motor lock	25544PE-SV .6 / .7
	25544HR-PE-SV .6 / .7
mFlipLock access motor lock / with evaluation contacts	25574PE-SV .6 / .7
	25574PE-SV-FF .6 / .7
	25574HR-PE-SV-FF .6 / .7
	25574HR-PE-SV .6 / .7
mFlipLock e-drive / handle controlled motor lock	26576PBe-SV-FF .6 / .7
	26546PBa-SV .2 / .3
	26546PBe-SV .2 / .3
	26546HR-PBa-SV .2 / .3
	26546HR-PBe-SV .2 / .3
mFlipLock e-access / handle controlled motor with evaluation contacts	26576PBe-SV-FF .6 / .7
	26576HR-PBa-SV-FF .6 / .7
	26576HR-PBe-SV-FF .6 / .7
	26576PBa-SV .2 / .3
	26576PBe-SV .2 / .3
	26576HR-PBa-SV .2 / .3
	26576HR-PBe-SV .2 / .3

Certificate of constancy of performance

Annex 1 Page 4 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Family	Designation Wicona
mFlipLock / basis	6020784, 6020785, 6020786, 6020787
	6020736, 6020737, 6020738, 6020739, 6023878, 6023879, 6023880, 6023881
mFlipLock / standard	6023882, 6023883, 6023884, 6023885
	6020788, 6020789, 6020790, 6020791
	6022921, 6022922, 6022923, 6022924
	6020792, 6020793, 6020794, 6020795, 6020796, 6020797, 6020798, 6020799
	6023886, 6023887, 6023888, 6023889, 6023890, 6023891, 6023892, 6023893, 6023558, 6023559, 6023560, 6023561, 6023562, 6023563, 6023564, 6023565
	6023378, 6023379, 6023380, 6023381, 6023898, 6023899, 6023900, 6023901
	6024091, 6024092, 6024093, 6024094, 6024095, 6024096, 6024097, 6024098
	6023975, 6023976, 6023977, 6023978, 6023979, 6023980, 6023981, 6023982
	6023967, 6023968, 6023969, 6023970, 6023971, 6023972, 6023973, 6023974
	6020926, 6020927, 6020928, 6020929
	6020808, 6020809, 6020810, 6020811
	6022913, 6022914, 6022915, 6022916, 6022917, 6022918, 6022919, 6022920
	6023382, 6023383, 6023384, 6023385, 6023490, 6023491, 6023492, 6023493, 6023578, 6023579, 6023580, 6023581, 6023582, 6023583, 6023584, 6023585
	mFlipLock check / contact lock
6020101, 6020102, 6020103, 6020104, 6020105, 6020106, 6020107, 6020108	
6020109, 6020110, 6020111, 6020112, 6020113, 6020114, 6020115, 6020116	
6020930, 6020931, 6020932, 6020933	
6023894, 6023895, 6023896, 6023897, 6023566, 6023567, 6023568, 6023569	
6020934, 6020935, 6020936, 6020937, 6020938, 6020939, 6020940, 6020941	
6023621, 6023483, 6023484, 6023485, 6023486, 6023487, 6023488, 6023489, 6023570, 6023571, 6023572, 6023573, 6023574, 6023575, 6023576, 6023577	

Certificate of constancy of performance

Annex 1 Page 5 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

	6020117, 6020118, 6020119, 6020120,6020121, 6020122, 6020123, 6020124, 6020125, 6020126, 6020127, 6020128, 6020129, 6020130, 6020131, 6020132
	6020942, 6020943, 6020944, 6020945
	6020962, 6020963, 6020964, 6020965
	6020966, 6020967, 6020968, 6020969
	6023494, 6023495, 6023496, 6023497, 6023586, 6023587, 6023588, 6023589
	6020946, 6020947, 6020948, 6020949, 6020950, 6020951, 6020952, 6020953
	6023498, 6023499, 6023500, 6023501, 6023502, 6023503, 6023504, 6023505, 6023590, 6023591, 6023592, 6023593, 6023594, 6023595, 6023596, 6023597
mFlipLock drive motor lock	6020812, 6020813, 6020814, 6020815
	6023506, 6023507, 6023508, 6023509, 6023598, 6023599, 6023600, 6023601
mFlipLock access motor lock / with evaluation contacts	6020954, 6020955, 6020956, 6020957
	6020958, 6020959, 6020960, 6020961
	6020133, 6020134, 6020135, 6020136, 6020137, 6020138, 6020139, 6020140
	6023622, 6023510, 6023511, 6023512, 6023602, 6023603, 6023604, 6024170
mFlipLock e-drive / handle controlled motor lock	-/-
	6023513, 6023514, 6023515, 6023516, 6023517, 6023518, 6023519, 6023520
	6023521, 6023522, 6023523, 6023524, 6023525, 6023526, 6023527, 6023528, 6023605, 6023606, 6023607, 6023608, 6023609, 6023610, 6023611, 6023612
mFlipLock e-access / handle controlled motor with evaluation contacts	-/-
	6020141, 6020142, 6020143, 6020144, 6020145, 6020146, 6020147, 6020148, 6020149, 6020150, 6020151, 6020152, 6020153, 6020154, 6020155, 6020156
	6023529, 6023530, 6023531, 6023532, 6023533, 6023534, 6023535, 6023536
	6023537, 6023538, 6023539, 6023540, 6023541, 6023542, 6023543, 6023544, 6023613, 6023614, 6023615, 6023616, 6023617, 6023618, 6023619, 6023620

Certificate of constancy of performance

Annex 1 Page 6 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Accessories:

No.	Designation	Designation Assa Abloy
1.	XL-forend extensions	Lengths of 350 mm, 550 mm and 800 mm Widths of forends 18 mm - 24 mm x 3 mm
2.	Flap striking plate	B-23421.HRE1243 B-23421.HRE4233 B-23421.RE3243 B-23421.RE6233 B-23421.R9243 B-24421.R9243 BV-24421.HR3243 BV-24421.HR3733 BV-24421.R3733 BV-24421.HR6233-24 BV-24421.HR6233-29,5 BV-24421.R6233-29,5 BV-24421.R6233-24 BV-24421.R3243
3.	Angled striking plate	B-23421.HRE1141/42 B-23421.HRE4131/42 B-23421.RE3141/42 B-23421.RE6131/32 B-23421.R9141/42 B-24421.R9141/42 BV-24421.R3631/32 BV-24421.HR3141/42 BV-24421.HR3631/32 BV-24421.R3141/42 BV-24421.R3641/42

Certificate of constancy of performance

Annex 1 Page 7 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Designation	Designation Assa Abloy
4.	Flat striking plate	B-23421.HRE7333 B-23421.RE5333-24 B-23421.RE9333 B-23421.R9333 BV-24421.HR6333 BV-24421.R5333-20 BV-24421.R5333-24 BV-24421.R6333 BV-25574.RE-FF.5333-20e BV-25574.RE-FF.5333-24e
5.	U-Strike plate	B-23421.RE5931/32-24 B-23421.R9931/32-24 B-24421.R9931/32-24 BV-24421.HR6931/32-24 BV-24421.R6931/32-22 BV-24421.HR6931/32-22 BV-24421.R5931/32-24, BV-24421.R6931/32-22 BV-24421.R6931/32-24 BV-25574.RE-FF.5931/32-24U
6.	Milling strike plate	BV-23421.E3541/42-20 BV-23421.2541/42-20 BV-23421.3541/42-20 BV-23421.E3541/42-20 BV-24413.3541/42-20 BV-24421.H3541/42-20 BV-24421.2541/42-20
7.	Mediator strike plate	WICSTYLE 75 WICSTYLE 65

Certificate of constancy of performance

Annex 1 Page 8 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Designation	Designation Wicona
1.	XL-forend extensions	-/-
2.	Flap striking plate	6020735, 6022902, 6022903, 6023410, 6023861
3.	Angled striking plate	-/-
4.	Flat striking plate	6020768, 6020769, 6023396, 6023397, 6023411
5.	U-Strike plate	-/-
6.	Milling strike plate	-/-
7.	Mediator strike plate	6020999, 6020749

Certificate of constancy of performance

Annex 1 Page 9 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Locks

- sFlipLock basis
- sFlipLock standard
- sFlipLock check contact lock
- sFlipLock drive motor lock
- sFlipLock access motor lock
- sFlipLock e-drive handle controlled
- sFlipLock e-access handle controlled

Family	Designation Assa Abloy
sFlipLock / basis	13444PE .6 / .7
	13446PBa .2 / .3
	13446PBe .2 / .3
sFlipLock / standard	14444PE .6 / .7
	14444PE-TF
	14446PBa .2 / .3
	14446PBe .2 / .3
	14544M-PE-SV .6 / .7
	14544PE-SV .6 / .7
	14544PE-SV-TF .6 / .7
	14546PBa-SV .2 / .3
	14546PBe-SV .2 / .3
sFlipLock check / contact lock	14476PBa .2 / .3
	14476PBe .2 / .3
	14474PE .6 / .7
	14574PE-SV .6 / .7
	14574PE-SV-TF .6 / .7
	14576PBa-SV .2 / .3
	14576PBe-SV .2 / .3
sFlipLock drive motor lock	15544PE-SV .6 / .7
sFlipLock access motor lock / with evaluation contacts	15574PE-SV .6 / .7
sFlipLock e-drive / handle controlled motor lock	16546PBa-SV .2 / .3
	16546PBe-SV .2 / .3
sFlipLock e-access / handle controlled motor lock with evaluation contacts	16576PBa-SV .2 / .3
	16576PBe-SV .2 / .3

Certificate of constancy of performance

Annex 1 Page 10 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Family	Designation Wicona
sFlipLock / basis	6023951, 6023952, 6023953, 6023954, 6023955, 6023956, 6023957, 6023958
	6023967, 6023968, 6023969, 6023970, 6023971, 6023972, 6023973, 6023974, 6023975, 6023976, 6023977, 6023978, 6023979, 6023980, 6023981, 6023982
sFlipLock / standard	6023959, 6023960, 6023961, 6023962, 6023963, 6023964, 6023965, 6023966
	6023983, 6023984, 6023985, 6023986, 6023987, 6023988, 6023989, 6023990
	6023991, 6023992, 6023993, 6023994, 6023995, 6023996, 6023997, 6023998, 6023999, 6024000, 6024001, 6024002, 6024003, 6024004, 6024005, 6024006
	6022973, 6022974, 6022975, 6022976
	6024031, 6024032, 6024033, 6024034, 6024035, 6024036, 6024037, 6024038
	6023354, 6023355, 6023356, 6023357, 6024039, 6024040, 6024041, 6024042
	6024043, 6024044, 6024045, 6024046, 6024047, 6024048, 6024049, 6024050, 6024051, 6024052, 6024053, 6024054, 6024055, 6024056, 6024057, 6024058
sFlipLock check / contact lock	6024015, 6024016, 6024017, 6024018, 6024019, 6024020, 6024021, 6024022, 6024023, 6024024, 6024025, 6024026, 6024027, 6024028, 6024029, 6024030
	6024007, 6024008, 6024009, 6024010, 6024011, 6024012, 6024013, 6024014
	6024059, 6024060, 6024061, 6024062, 6024063, 6024064, 6024065, 6024066
	6024083, 6024084, 6024085, 6024086, 6024087, 6024088, 6024089, 6024090
	6024067, 6024068, 6024069, 6024070, 6024071, 6024072, 6024073, 6024074, 6024075, 6024076, 6024077, 6024078, 6024079, 6024080, 6024081, 6024082

Certificate of constancy of performance

Annex 1 Page 11 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

sFlipLock drive motor lock	6023328, 6023329, 6023330, 6023331, 6023358, 6023359, 6023360, 6023361
sFlipLock access motor lock / with evaluation contacts	6023337, 6023338, 6023339, 6023340, 6023366, 6023367, 6023368, 6023369
sFlipLock e-drive / handle controlled motor lock	6023362, 6023363, 6023364, 6023365, 6024099, 6024100, 6024101, 6024102, 6024107, 6024108, 6024109, 6024110
sFlipLock e-access / handle controlled motor lock with evaluation contacts	6023370, 6023371, 6023372, 6023373, 6024103, 6024104, 6024105, 6024106, 6024111, 6024112, 6024113, 6024114

Certificate of constancy of performance

Annex 1 Page 12 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Accessories:

No.	Designation	Designation Assa Abloy
1.	Flap striking plate	BV-14421.H3243 BV-14421.R6233-24 BV-14421.R6233-29,5
2.	Angled striking plate	BV-14421.R3141-42 BV-14421.R3631-32
3.	Flat striking plate	BV-14421.R6333 BV-14421.R6833
4.	U-Strike plate	BV-14421.R6931/32-24
5.	Milling strike plate	BV-14421.3541/42-20
6.	Mediator strike plate	WICSTYLE 75 WICSTYLE 65

No.	Designation	Designation Wicona
1.	Flap striking plate	6020735, 6022902, 6022903, 6023410, 6023861
2.	Angled striking plate	-/-
3.	Flat striking plate	6020768, 6020769, 6023396, 6023397, 6023411
4.	U-Strike plate	-/-
5.	Milling strike plate	-/-
6.	Mediator strike plate	6020999, 6020749

Certificate of constancy of performance

Annex 1 Page 13 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

2. Emergency exit devices as per EN 179 : 2008 for double leaf doorsets: handle operation

Classification:	3	7	7	B	1	3	2	2	A	A
------------------------	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------

For Assa Abloy:

Back set 30 up to 80 mm
Distance 92 mm for PZ and 94 mm for RZ
Forend (18 up to 24) mm x 3 mm

for Wicona:

Back set 35 and 45 mm
Distance 92 mm for PZ and 94 mm for RZ
Forend 22 mm x 3 mm

Intended use: Intended for use on doors in escape routes with requirements for fire resistance and smoke control

Reference-report: 17-000296-PR05 dated 06.09.2021
Reference-report: 17-000296-PR12 dated 21.08.2019

Certificate of constancy of performance

Annex 1 Page 14 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Locks:

- mFlipLock standard
- mFlipLock check contact lock
- mFlipLock drive motor lock
- mFlipLock access motor lock
- mFlipLock e-drive handle controlled
- mFlipLock e-access handle controlled

Family	Designation Assa Abloy
mFlipLock / standard	24444PE-ZF .6 / .7
	24444PE-TF-ZF .6/.7
	24444HR-PE-ZF .6 / .7
	24446PBa-ZF .2 / .3
	24446HR-PBa-ZF .2 / .3
	24544PE-SV-ZF .6 / .7
	24544PE-SV-TF-ZF .6 / .7
	24544HR-PE-SV-ZF .6 / .7
	24444HR-PE-TF-ZF .6/.7
	24544HR-PE-SV-TF-ZF .6 / .7
	24546HR-PBa-SV-ZF .2/.3
	24546PBa-SV-ZF .2 / .3
mFlipLock check / contact lock	24474PE-ZF .6 / .7
	24474HR-PE-ZF .6 / .7
	24476PBa-ZF .6 / .7
	24476HR-PBa-ZF .6 / .7
	24574PE-SV-ZF .6 / .7
	24574PE-SV-FF-ZF .6 / .7
	24574PE-SV-TF-ZF .6 / .7
	24576PBa-SV-ZF .2 / .3
	24574HR-PE-SV-ZF .6/.7
	24576HR-PBa-SV-FF-ZF .2/.3
	24576HR-PBa-SV-ZF .2 / .3
	24574HR-PE-SV-TF-ZF .6 / .7
24574HR-PE-SV-FF-ZF .6 / .7	
mFlipLock drive motor lock	25544PE-SV-ZF .6 / .7
	25544HR-PE-SV-ZF .6 / .7

Certificate of constancy of performance

Annex 1 Page 15 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

mFlipLock access motor lock / with evaluation contacts	25574PE-SV-ZF .6 / .7
	25574PE-SV-FF-ZF .6 / .7
	25574HR-PE-SV-ZF .6 / .7
	25574HR-PE-SV-FF-ZF .6 / .7
mFlipLock e-drive / handle controlled motor lock	26546PBa-SV-ZF .2 / .3
	26546HR-PBa-SV-ZF .2/.3
mFlipLock e-access / controlled motor lock with evaluation contacts	26576PBa-SV-ZF .2 / .3
	26576HR-PBa-SV-ZF .2 / .3
	26576HR-PBa-SV-FF-ZF .2/.3

Certificate of constancy of performance

Annex 1 Page 16 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Family	Designation Wicona
mFlipLock / standard	6022925, 6022926, 6022927, 6022928
	6022989, 6022990, 6022991, 6022992
	6023633, 6023634, 6023635, 6023636, 6023649, 6023650, 6023651, 6023652
	6022929, 6022930, 6022931, 6022932
	6023641, 6023642, 6023643, 6023644, 6023657, 6023658, 6023659, 6023660
	6022977, 6022978, 6022979, 6022980
	6022937, 6022938, 6022939, 6022940
	6023346, 6023347, 6023348, 6023349, 6023386, 6023387, 6023388, 6023389
	6023637, 6023638, 6023639, 6023640, 6023653, 6023654, 6023655, 6023656
	6023665, 6023666, 6023667, 6023668, 6023673, 6023674, 6023675, 6023676
	6023390, 6023391, 6023392, 6023393, 6023350, 6023351, 6023352, 6023353
	6022981, 6022982, 6022983, 6022984
	mFlipLock check / contact lock
6023681, 6023682, 6023683, 6023684, 6023693, 6023694, 6023695, 6023696	
6022953, 6022954, 6022955, 6022956	
6023685, 6023686, 6023687, 6023688, 6023697, 6023698, 6023699, 6023700	
6022965, 6022966, 6022967, 6022968	
6023705, 6023707, 6023706, 6023708	
6022961, 6022962, 6022963, 6022964	
6022969, 6022970, 6022971, 6022972	
6023709, 6023710, 6023711, 6023712, 6023729, 6023730, 6023731, 6023732	
6020075, 6020076, 6020077, 6020078, 6020079, 6020080, 6020081, 6020082	
6023721, 6023722, 6023723, 6023724, 6023741, 6023742, 6023743, 6023744	
6023717, 6023718, 6023719, 6023720, 6023737, 6023738, 6023739, 6023740	
6023713, 6023714, 6023715, 6023716, 6023733, 6023734, 6023735, 6023736	

Certificate of constancy of performance

Annex 1 Page 17 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

mFlipLock drive motor lock	6022941, 6022942, 6022943, 6022944
	6023753, 6023754, 6023755, 6023756, 6023765, 602366, 6023767, 6023768
mFlipLock access motor lock / with evaluation contacts	6022945, 6022946, 6022947, 6022948
	6023749, 6023750, 6023751, 6023752
	6023757, 6023758, 6023759, 6023760, 6023769, 6023770, 6023771, 6023772
mFlipLock e-drive / handle controlled motor lock	6023761, 6023762, 6023763, 6023764, 6023773, 6023774, 6023775, 6023776
	6023777, 6023778, 6023779, 6023780
mFlipLock e-access / controlled motor lock with evaluation contacts	6023793, 6023794, 6023795, 6023796, 6023809, 6023810, 6023811, 6023812
	6023785, 6023786, 6023787, 6023788
mFlipLock e-access / controlled motor lock with evaluation contacts	6023801, 6023802, 6023803, 6023804, 6023817, 6023818, 6023819, 6023820
	6020083, 6020084, 6020085, 6020086, 6020087, 6020088, 6020089, 6020090

Certificate of constancy of performance

Annex 1 Page 18 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Accessories:

No.	Designation	Designation Assa Abloy
1.	XL-forend extensions	Length of 350 mm, 550 mm and 800 mm Widths of forends 18 mm - 24 mm x 3 mm
2.	Flap striking plate	B-23421.HRE1243 B-23421.HRE4233 B-23421.RE3243 B-23421.RE6233 B-23421.R9243 B-24421.R9243 BV-24421.HR3243 BV-24421.HR3733 BV-24421.R3733 BV-24421.HR6233-24 BV-24421.HR6233-29,5 BV-24421.R6233-29,5 BV-24421.R6233-24 BV-24421.R3243
3.	Angled striking plate	B-23421.HRE1141/42 B-23421.HRE4131/42 B-23421.RE3141/42 B-23421.RE6131/32 B-23421.R9141/42 B-24421.R9141/42 BV-24421.R3631/32 BV-24421.HR3141/42 BV-24421.HR3631/32 BV-24421.R3141/42 BV-24421.R3641/42

Certificate of constancy of performance

Annex 1 Page 19 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Designation	Designation Assa Abloy
4.	Flat striking plate	B-23421.HRE7333 B-23421.RE5333-24 B-23421.RE9333 B-23421.R9333 BV-24421.HR6333 BV-24421.R5333-20 BV-24421.R5333-24 BV-24421.R6333 BV-25574.RE-FF.5333-20e BV-25574.RE-FF.5333-24e
5.	U-Strike plate	B-23421.RE5931/32-24 B-23421.R9931/32-24 B-24421.R9931/32-24 BV-24421.HR6931/32-24 BV-24421.R6931/32-22 BV-24421.HR6931/32-22 BV-24421.R5931/32-24, BV-24421.R6931/32-22 BV-24421.R6931/32-24 BV-25574.RE-FF.5931/32-24U
6.	Milling strike plate	BV-23421.E3541/42-20 BV-23421.2541/42-20 BV-23421.3541/42-20 BV-23421.E3541/42-20 BV-24413.3541/42-20 BV-24421.H3541/42-20 BV-24421.2541/42-20

Certificate of constancy of performance

Annex 1 Page 20 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Designation	Designation Wicona
1.	XL-forend extensions	6022994, 6022995, 6020766, 6020767, 6022997, 6022998, 6024116, 6024117, 6024118, 6024119, 6024120, 6024121
2.	Flap striking plate	6020735, 6022902, 6022903, 6023410, 6023861
3.	Angled striking plate	-/-
4.	Flat striking plate	6020768, 6020769, 6023396, 6023397, 6023411
5.	U-Strike plate	-/-
6.	Milling strike plate	-/-

Certificate of constancy of performance

Annex 1 Page 21 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Locks:

- sFlipLock standard
- sFlipLock check contact lock
- sFlipLock drive motor lock
- sFlipLock access motor lock
- sFlipLock e-drive handle controlled
- sFlipLock e-access handle controlled

Family	Designation Assa Abloy
sFlipLock / standard	14444PE-ZF .6 / .7
	14446PBa-ZF .2 / .3
	14544PE-SV-ZF .6 / .7
	14544PE-SV-TF-ZF
	14546PBa-SV-ZF .2 / .3
	14444PE-ZF-TF
sFlipLock check / contact lock	14474PE-ZF .6 / .7
	14476PBa-ZF .2 / .3
	14574PE-SV-ZF .6 / .7
	14574PE-SV-TF-ZF .6 / .7
	14576PBa-SV-ZF .2 / .3
sFlipLock drive motor lock	15544PE-SV-ZF .6 / .7
sFlipLock access motor lock / with evaluation contacts	15574PE-SV-ZF .6 / .7
sFlipLock e-drive / handle controlled motor lock	16546PBa-SV-ZF .2 / .3
sFlipLock e-access / handle controlled motor lock with evaluation contacts	16576PBa-SV-ZF .2 / .3

Certificate of constancy of performance

Annex 1 Page 22 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Family	Designation Wicona
sFlipLock / standard	6020883, 6020884, 6020885, 6020886, 6020907, 6020908, 6020909, 6020910
	6020899, 6020900, 6020901, 6020902, 6022891, 6022892, 6022893, 6022894
	6022933, 6022934, 6022935, 6022936, 6022973, 6022974, 6022975, 6022976,
	6023432, 6023433, 6023434, 6023435
	6022957, 6022958, 6022959, 6022960, 6022985, 6022986, 6022987, 6022988
	6020891, 6020892, 6020893, 6020894, 6020986, 6020987, 6020988, 6020989
sFlipLock check / contact lock	6023645, 6023646, 6023647, 6023648, 6023669, 6023670, 6023671, 6023672
	6023661, 6023662, 6023663, 6023664, 6023677, 6023678, 6023679, 6023680
	6023689, 6023690, 6023691, 6023692, 6023745, 6023746, 6023747, 6023748
	6023701, 6023702, 6023703, 6023704, 6023781, 6023782, 6023783, 6023784
	6023725, 6023726, 6023727, 6023728, 6023789, 6023790, 6023791, 6023792
sFlipLock drive motor lock	6023797, 6023798, 6023799, 6023800, 6023813, 6023814, 6023815, 6023816
sFlipLock access motor lock / with evaluation contacts	6023805, 6023806, 6023807, 6023808, 6023821, 6023822, 6023823, 6023824
sFlipLock e-drive / handle controlled motor lock	6023827, 6023828, 6023829, 6023830, 6023835, 6023836, 6023837, 6023838
sFlipLock e-access / handle controlled motor lock with evaluation contacts	6023831, 6023832, 6023833, 6023834, 6023839, 6023840, 6023841, 6023842

Certificate of constancy of performance

Annex 1 Page 23 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Accessories:

No.	Designation	Designation Assa Abloy
1.	Flap striking plate	BV-14421.H3243 BV-14421.R6233-24 BV-14421.R6233-29,5
2.	Angled striking plate	BV-14421.R3141-42 BV-14421.R3631-32
3.	Flat striking plate	BV-14421.R6333 BV-14421.R6833
4.	U-Strike plate	BV-14421.R6931/32-24
5.	Milling strike plate	BV-14421.3541/42-20
6.	Panic passive leaf locking	24413-M, 24413-M-TF, 24473-M, 24473-M-TF, 24413-H, 24413-H-TF, 24473-H, 24473-H-TF
7.	Forends to panic passive leaf locking	14413-H-STL-V.3143, 14413-H-STW-V.3141-42, 14413-M-STU-V.6931-32, 14413-M-STL-V.6233, 14413-M-STF-V.6333
8.	Floor-closing recess	1727
9.	Switching lock	1730
10.	Square mandrel	5961, 5968, 5496
11.	Bar guidance	1726
12.	Round tube	1725
13.	Round bar	1724
14.	Reinforcement set	1723

Certificate of constancy of performance

Annex 1 Page 24 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Designation	Designation Wicona
1.	Flap striking plate	6020735, 6022902, 6022903, 6023410, 6023861
2.	Angled striking plate	-/-
3.	Flat striking plate	6020768, 6020769, 6023396, 6023397, 6023411
4.	U-Strike plate	-/-
5.	Milling strike plate	-/-
6.	Panic passive leaf locking	6023012, 6023013, 6023014, 6023015, 6023008, 6023009, 6023010, 6023011, 6023004, 6023005, 6023006, 6023007, 6023000, 6023001, 6023002, 6023003, 6023394, 6023395, 6023825
7.	Forends to panic passive leaf locking	6020755, 6022993, 6020756, 6020765, 6022900, 6022901, 6023264, 6023860, 6023862
8.	Floor-closing recess	6920087, 6920170, 6920171, 6920048, 69200740, 6021069, 6021984, 6020729
9.	Switching lock	6020773
10.	Square mandrel	6030221, 6030222
11.	Bar guidance	-/-
12.	Round tube	6020775, 6023265
13.	Round bar	6020774, 6023091
14.	Reinforcement set	6024115

Certificate of constancy of performance

Annex 1 Page 25 of 27
 Certificate holder: ASSA ABLOY (Schweiz) AG
 Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

External or internal fitting

No.	Manufacturer	Designation Assa Abloy	Coding
1.	Assa Abloy (Schweiz) AG	5496 (square spindle), 5967, 5968, 5972, 5974, 5978, 5979, 5972, N49674909300000, N49624909300000, N44274909400000, N44224909400000	-/-
2.	MTS Metallbaubeschlage AG	14.2890.8278, 14.2892.7002.78, 14.2852.7294.0, 14.2850.8294, 14.5780.7294, 14.5780.6294, 14.5770.7294, 14.5770.6294	-/-
3.	Dormakaba Holding AG	elologic c-lever	-/-
4.	Glutz AG	5064, 5827-53, 5620C, 5175, 5825-50E, 5618C, 5038, 5046, 5054, 5055, 5059, 5061, 5062, 5064, 5065, 5066, 5069, 5089-5618, 5092, 5096, 5098, 5099, 5162, 5175-5618, 6031, 6032, 6045, 5066, 6046	-/-
5.	HOPPE Holding AG	E50G/3346/138GFI, E138G1/3346, FS-E50G/3346/1401GF2, FS-E50G/3346/1401GF2, FS-E1401GF2/3346	DO20.5.01, DO20.5.02, DO20.5.02-RD, DO20.5.05, DO20.7.01, DO20.7.02, DO20.20.01, DO20.20.02, 20.20.02-RD
6.	ECO Schulte GmbH & Co. KG	D-110.AL, D-110 ER, D-115.AL, D-115 ER, D-116.AL, D-116.ER, D-120.AL, D-120 ER, D-330.AL, D-330 ER, D-335.ER, D-410.AL, D-410 ER, D-415.AL, D-415 ER, D-510.AL, D-510 ER, D-515.AL, D-515 ER	-/-

Certificate of constancy of performance

Annex 1 Page 26 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

No.	Manufacturer	Designation Assa Abloy	Coding
7.	HEWI Heinrich Wilke GmbH	162XAH11.530 162XAH52.640 111XAH11.110 111R11.210 111R11.230 111R11.240	-/-
8.	Grundmann Beschläge GmbH	1554FHA, 1754FHA, 2254FHA, 2454FHA, 2554FHA	-/-
9.	MEGA GOSSAU AG	33.603, 33.604, 34190. 33103_34160, 33203_34160, 33104_34190, 33204_34190, 33253, 33254, 33237, 33623, 33624, Armin Meili	-/-
10.	HAFI Beschläge GmbH	302-9/288/283, 299-9/830/831 302-9/818	-/-
11.	Schlossfabrik Heusser AG	655S42, 653S20, 653S13, 655S38, 655S20, 655S, 656D	-/-

Certificate of constancy of performance

Annex 1 Page 27 of 27
Certificate holder: ASSA ABLOY (Schweiz) AG
Date of issue: 02.01.2023



Certificate No.: 0757-CPR-229PANIK-6039631-23-9

Field of application:

Maximum door mass:

– for "door mass" (3rd digit in the classification key) = class 6: up to 200 kg

– for "door mass" (3rd digit in the classification key) = class 7: up to 300 kg

Maximum door height: 3.000 mm

Maximum door width: 1.320 mm

Explanations: The different product families can have the following functions:

Function B:

Initial position: Function from inside and outside: Passage from both sides via the lever handle, the latch is retracted, the lock follower is engaged on both sides.

Intended use: For doors that must allow passage from inside and outside at times.

Function C:

Initial position: Function from the inside: Exit, the door can be opened at any time in the escape direction using the lever handle. Function from outside: Idle, as the follower is decoupled.

Intended use: For doors where unauthorised opening from the outside must be prevented as a matter of principle. The door cannot be left unlocked accidentally.

Function D:

Initial position: Function from inside and outside: Passage from both sides via the lever handle, the latch is retracted, the lock follower is engaged on both sides.

Intended use: For doors that must allow passage from inside and outside at times.

Function E:

Initial position: Function from the inside: Exit, the door can always be opened in escape direction. Function from outside: Only a fixed knob or push handle may be used as a fitting. The door can only be opened with the key. The latch is retracted in the process.

Intended use: For doors where unauthorised opening from the outside must be prevented as a matter of principle. The door cannot be left unlocked accidentally.

Lock cylinder: All types of locking cylinders with freewheel function have no influence on perfect functioning.

*In the course of the tests, closures with inserted profile cylinders according to DIN 18252 (PZ version) were always tested. In the case of round cylinder designs, dimensional adjustment must be made to ensure that the function of the locks is guaranteed.